

Summer water level standards went into effect June 1st. All lakes are within summer standards. The table below gives current lake levels and compares to the summer standards. Levels are typically expected to decline during summer unless rainfall is above normal. This summer rainfall is below normal.

Recent lake levels, MINIMUM AND MAXIMUM SUMMER water level STANDARDS (*feet above sea level NGVD 29*)

LAKE	RECENT LEVEL	SUMMER MINIMUM	SUMMER MAXIMUM	WATER LEVEL STATUS	DAM STATUS
ANNABESSACOOK LAKE	169.32 8/24	168.7	170.35	Within summer standards. 10 1/2 inches below full pond.	All boards in. Flow is leakage only.
COBBOSSEE LAKE	166.57 8/24	166.1	167.6	Within summer standards. 9 inches below full pond.	1 gate open 2 inches. Outflow unavailable.
COCHNEWAGON LAKE	270.48 8/24	269.4	271.0	Within summer standards. 5 inches below full pond.	Gate open 1 inch.
MARANACOOK LAKE	210.97 8/25	210.0	212.0	Within summer standards. 6 inches below revised full pond elevation.	Gate barely open, outflow 1 cfs plus additional flow from leakage at side spillway.
NARROWS PONDS	170.85 8/24	170.5	172.0	Within summer standards. 14 inches below full pond.	none
PLEASANT POND and Cobbossee Stream	134.88 8/25	134.0	135.0	Within summer standards. 1 1/2 inches below full pond.	1 gate open 2 inches. Outflow = 17.5 cfs
TORSEY POND	262.38 8/22	262.0	263.5	Within summer standards. 8 inches below revised full pond.	1 gate open 0.5 inch.
WILSON POND and Dexter & Berry Ponds	240.99 8/24	240.2	241.7	Within summer standards. 6 inches below full pond.	2 boards out, slight outflow
WOODBURY POND /Tacoma Lakes *Not feet above sea level.	7.1* 8/24	none	7.5	Within TLA maximum goal of 7.5 on staff gage. 5 inches below full pond.	Gates closed

DAM and Project News:

- ◆ Repairs were completed yesterday on the Mill Pond Dam owned by Tex-Tech on Wilson Stream, below the Wilson Pond Dam.
- ◆ A utility water line has recently been installed under Maranacook Lake at the outlet and is progressing on adjacent land.
- ◆ The Town of Monmouth has hired Commercial Divers Inc., to be assisted by the Public Works Dept., to rebuild the spillway stop board structure to fix the board leakage at the Martin Hovey Dam on Annabessacook Lake.
- ◆ Municipal owners of the New Mills Dam on Cobbossee Stream in Gardiner continue to make plans for maintenance repairs in the fall. An early drawdown of Pleasant Pond and Cobbossee Stream will be necessary.

8/25/2026

